GOVERNMENT OF INDIA
POWER
LOK SABHA

UNSTARRED QUESTION NO:4800
ANSWERED ON:15.12.2016
Breakdown in NTPC Units
Nete Shri Ashok Mahadeorao

Will the Minister of POWER be pleased to state:

(a) the details of units of NTPC set up in backward areas in the country;

(b) the details of breakdowns occurred in the said units during each of the last three years and the date, unit-wise; and

(c) the corrective measures taken for providing recurrence of such faults/ breakdowns?

Answer

THE MINISTER OF STATE (INDEPENDENT CHARGE) FOR POWER,
COAL, NEW & RENEWABLE ENERGY AND MINES

(SHRI PIYUSH GOYAL)

(a) : The details of units of NTPC, set up in Backward areas in the Country, are given at Annex-I.

(b) : The details regarding breakdowns (Forced Outages %) in the aforementioned units are given at Annex-II.

(c) : The corrective measures taken to prevent breakdowns (forced outages) at NTPC plants are as follows:

â€¢ Each failure is analyzed by an expert committee within the company and corrective actions are taken based on their recommendations. Wherever required, assistance of Original Equipment Manufacturer is also taken.

â€¢ Detailed condition monitoring of each equipment is done in a scheduled manner. Based on the results, preventive and predictive maintenance are carried out to prevent such failures.

****